

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:11 pm

PWS ID: UTAH29013 **Name:** WOLF CREEK COUNTRY CLUB
Legal Contact: WOLF CREEK COUNTRY CLUB **Rating:** Approved
 ROB THOMAS **Rating Date:** 08/28/1990
Address: 3900 N WOLF CREEK DR **Activity Status:** Active
 EDEN, UT 84310
Phone Number: 801-745-3737
City Served (Area):
County: WEBER COUNTY

System Type: Community **Last Inv Update:** 06/16/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/01/2008 **Total Dsgn Cap:**
Population: 2,000 **Surveyor:** PETER T KEERS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	THOMAS, ROB	MANAGER	801-430-4647		rthomas@wolfcreekutah.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	984
			984 Total Svc Connections

Storage

Total Storage: 700,000 GAL **Number of Units:** 5 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	HIGHLANDS TANK	Ground	400,000 GAL	Concrete		A	NO
ST004	EDEN HILLS TANK	Ground	50,000 GAL	Concrete		A	NO
ST005	WARM SPRING/ARTESIAN WET WE	Reservoir				A	NO
ST001	SNOWFLAKE TANK	Ground	55,000 GAL	Concrete		I	NO
ST002	WOLF CREEK TANK	Ground	250,000 GAL	Concrete		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	WARM SPRING PUMP STATION	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WOLF CREEK SPRING	Inactive	SP				Yes	GW	Permanent		
WS002	WARM SPRING ARTESIAN V	Active	WL	8	400 GPM		Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS003	HIGHLANDS WELL	P	WL				Yes	GW	Permanent		
WS004	EDEN HILLS WELL	Active	WL				No	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*